




A (1 : 5)
Tylko tylne podpory
Only rear legs

K-54-13AG-001-M
C-135x45x18x3
S350 ZM 430

K-54-36-52-001-M


Ilość do jednej podpory
Quantity per support
10x K-28-30
10x K-51
10x K-21

K-54-13UG-001-M
C-135x45x18x3
S350 ZM 430

Uwaga:
Systemy wolnostojące uzależnione są od strefy obciążenia śniegiem i wiatrem.
• Wiatr - wartość obciążenia wg. normy PN-EN 1991-1-4
• Śnieg - wartość obciążenia wg. normy PN-EN 1991-1-3
Montaż przedstawionego stołu należy wykonać na podstawie instrukcji montażu.

Attention:
Freestanding systems depend on the snow and wind load zones.
• Wind - load value according to the PN-EN 1991-1-4 standard
• Snow - load value according to the PN-EN 1991-1-3 standard
Installation of the presented table must be carried out based on the installation instructions.

0			-	-
Rev	Rev. Date	Description	Revised By	Approved By
Designed by	Material	Weight	Date	ISO
Dawid Harz	-	917,274 kg	27.03.2026	(E)
KENO Sp. z o.o.			Construction K-54 Vertical	Format
Ul. Daszyńskiego 609, 44-151 Gliwice			2382,0 mmx1134,0 mmx35,0 mm	A3
NIP PL6312671983			K-54-00-GS-MO-2V-003-A	Dim without to ISO2768-M ISO13920-B
			Scale	Sheet
			1 : 55	1 / 2



Uwaga:
Systemy wolnostojące uzależnione są od strefy obciążenia śniegiem i wiatrem.
• Wiatr - wartość obciążenia wg. normy PN-EN 1991-1-4
• Śnieg - wartość obciążenia wg. normy PN-EN 1991-1-3
Montaż przedstawionego stołu należy wykonać na podstawie instrukcji montażu.

Attention:
Freestanding systems depend on the snow and wind load zones.
• Wind – load value according to the PN-EN 1991-1-4 standard
• Snow – load value according to the PN-EN 1991-1-3 standard
Installation of the presented table must be carried out based on the installation instructions.

LIST OF PARTS				
NUMBER	QTY	PART NUMBER		NAME OF PART
1	134	K-21		Nut M10
2	110	K-51		Washer 10,5
3	40	K-18		hex socket screw M8x20
4	8	K-06		End clamp
5	32	K-05		Middel clamp
8	40	K-54-24		Diamond-shaped nut
12	6	K-54-14 2289mm		Low support
13	6	K-54-22 2V 3893mm		Rafter
17	2	K-54-08 2669mm		Strut
19	4	K-54-174 4716mm		End Beam
20	24	K-69-M10		Srew ISO 7380-1 M10x20
21	4	K-54-05		Beam Connector
23	110	K-28 M10x30		Screw M10x30
24	6	K-54-13UG 1719mm		High support, Under Ground
25	6	K-54-13AG 1956mm		High support, Above Ground
26	6	K-54-36		Support Connector
27	4	K-54-17B 5770mm		Base Beam
0			-	-
Rev	Rev. Date	Description		Revised By Approved By
Designed by Dawid Harz		Material -	Weight 917,274 kg	Date 27.03.2026
KENO Sp. z o.o.		Construction K-54 Vertical		Format A3
Ul. Daszyńskiego 609, 44-151 Gliwice		2382,0 mmx1134,0 mmx35,0 mm		Dim without to ISO2768-M
NIP PL6312671983		K-54-00-GS-MO-2V-003-A		ISO13920-B
		Scale 1 : 55		Sheet 2 / 2